

# ATG ACCESS LTD

## PAS 68: 2007 TEST USING EUROPEAN SPECIFICATION 7.5 TONNE VEHICLE

### V Rising Bollard 7500 80/0/10

**Test Agency**

TRL Ltd  
Crowthorne House  
Nine Mile Ride  
Workingham  
Berkshire  
RG40 3GA



**Test Article**

Type SP1000 Single Bollard

**Test Vehicle**

Type Two axle rigid lorry, curtain sided  
Kerb Weight 3725 kg  
Test Weight 7500 kg

**Impact Conditions**

	<b>Target</b>	<b>Achieved</b>
Impact Speed	80 km/h	80 km/h
Impact Angle	90°	90°
Impact Energy	1852kj	1870kj


**Result**


The vehicle was immobilised

**This product is also certified as a static variant when installed in a suitable foundation**

**Manufacturer**

ATG Access Ltd  
CoBaCo House  
North Florida Road  
Haydock Industrial Estate  
Haydock  
WA11 9TP

Signed:   
Robert Ball  
Engineering Dept

  
Signed: .....  
Glenn Cooper  
Director